



AGA CERTIFIED PRODUCT

Certificate Holder: **KARL DUNGS GMBH & CO KG**
ABN/ACN No. (if applicable): N/A
Manufacturer: **Karl Dungs GmbH & Co KG**
Agent (if applicable): **Techrite Controls Australia Pty Ltd**
Type of Component: **Pressure Switch for Air or Gas**
Model No. & Description: **DUNGS**
(Refer www.aga.asn.au for more details)

GW 3 A5, GW 10 A5, GW 50 A5, GW 150 A5 – (50 kPa)
GW 500 A5 – (60 kPa)
GW 3 A5/1, GW 10 A5/1, GW 50 A5/1, GW150 A5/1 – (50 kPa)
GW 500 A5/1 – (60 kPa)
GW 3 A6, GW 10 A6, GW 50 A6, GW 150 A6 – (50 kPa)
GW 500 A6 – (60 kPa)
GW 3 A6/1, GW 10 A6/1, GW 50 A6/1, GW 150 A6/1 – (50 kPa)
GW 500 A6/1 – (60 kPa)

Note:
GW...A5, A6: Short response time during pressure fluctuations
GW...A5/1, A6/1: Slow response time during short-term pressure fluctuations by additional damping nozzle.

Relevant Standard(s): **AS 4628 – 2005 (Incorporating Amdt 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **2 October 2000**

Certificate No: **6062**

This copy valid from: **21 April 2020**

Refer specification issue: **04**